




SEISMIC MOUNTING NOTE:
FOR SEISMIC CERTIFIED UNITS,
MOUNT WITH THE FOLLOWING HARDWARE:
WALL MOUNTED (STEEL)
Ø9.53 [1.375] Dia. SAE GRADE 1/ ASTM A307 BOLTS.
WALL MOUNTED (CONCRETE)
Ø9.53 [1.375] Dia. HILTI KWIK BOLT TZ-CS WITH MIN.
EMBEDMENT 50.8 [2.00]; EDGE DISTANCE OF 101.6 [4.00]
ON A 101.6 [4.00] THICK 4000 PSI CONCRETE WALL.
HARDWARE TO COMPLY WITH SPECIFICATIONS
ON ADV-7456.



NOTE:
ALLOW FOR MINIMUM DOOR
SWING CLEARANCE OF 864 [34.0]
IN FRONT OF THE CABINET.

NOTES:
DIMENSIONS IN [] ARE INCHES.


FINISH - ANSI 49 GRAY.

REFER TO OPERATORS MANUAL PRIOR TO
INSTALLATION AND OPERATION OF SWITCH.

FOR SEISMIC CERTIFIED UNITS, REFER TO
ADV-7456 AND INSTALLATION INSTRUCTIONS.

SEE ADV-8565 FOR FULL MODEL CODE DEFINITION									
STYLE	MECHANISM	TRANSITION	MPAC LOGIC	VOLTS	POLES	NEUTRAL	ENCLOSURE	AMPS	CONNECTION
KSS	SPECIFIC	STANDARD	750, 1200	208-480	3, 4	SOLID, SW	1, 3R	800, 1000	STANDARD

REV	DATE	REVISION	BY	UNLESS OTHERWISE SPECIFIED - 1) DIMENSIONS ARE IN MILLIMETERS 2) TOLERANCES ARE:	SURFACE FINISH		THIRD ANGLE PROJECTION		APPROVALS		DATE		TITLE	
-	8-23-13	NEW DRAWING [CT54441]	BTW	X.XX X.X X ANGLES	MAX.		THIRD ANGLE PROJECTION		DRAWN		8-23-13		POWER SYSTEMS, KOHLER, WI 53044 U.S.A.	
A	3-5-19	(A-5)(A-6) REMOVED SEISMIC PART GM81715 [CT193069]	ZHK						CHECKED		8-23-13		PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.	
									APPROVED		8-23-13		THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO.	
													DRAWING NO.	
													ADV-8592	
													SHEET 1 of 2	
													D	



AMPERAGE	POLE	A	B
800	3	293 [11.5]	80 [3.2]
	4		
1000	3	303 [11.9]	100 [3.9]
	4		

SCREW TYPE TERMINALS FOR EXTERNAL POWER CONNECTION			
SWITCH RATING (AMPS)	RANGE OF AL-CU WIRE SIZES		
	CONTACTOR (PER PHASE)	NEUTRAL (3 POLE)	GROUND
	800 1000	(2) 1/0 - 750 KCMIL (4) #2 - 600 KCMIL	(3) #4 - 600 KCMIL OR (6) 1/0 - 250 KCMIL

NOTE: 4 POLE UNIT SHOWN.

WEIGHT IN Kg [LBS]		
AMPS	3 POLE	4 POLE
800	226 [498]	236 [520]
1000	231 [509]	241 [531]

REV	DATE	REVISION	BY	UNLESS OTHERWISE SPECIFIED - 1) DIMENSIONS ARE IN MILLIMETERS 2) TOLERANCES ARE:	TITLE
-	8-23-13	NEW DRAWING [CT54441]	BTW	X.XX X.X X ANGLES	KOHLER CO. METRIC PRO-E POWER SYSTEMS, KOHLER, WI 53044 U.S.A. THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED. DIMENSION PRINT
A	5-3-19	(B-5)(D-5) UPDATED NOTES [CT193069]	ZHK	THIRD ANGLE PROJECTION	
				APPROVALS DATE	
				CHECKED BTW 8-23-13	
				APPROVED MTL 8-23-13	
				SCALE CAD NO. SHEET 2 of 2	
				ADV-8592	D